



Sheridan Japanese School Healthy and Safe Schools Plan Adopted November 21 2016

The Sheridan Japanese School has developed this Healthy and Safe Schools Plan to meet the requirements of OAR 581-022-2223, OAR 584-024-0275, ORS 333.167, ORS 634.700 through 634-750.

1. Responsible Person

The person responsible for maintaining the Healthy and Safe Schools Plan is the Executive Director, Andrew Scott. The contact information is:

e-mail: sjsexecdirector@gmail.com

Phone: 503-843-3400

Address: 430 SW Monroe St, Sheridan OR 97378

2. List of Buildings

This plan covers the Sheridan Japanese School building and grounds located at 430 SW Monroe Street, Sheridan, Oregon.

3. Radon

The Sheridan Japanese School has developed a radon testing plan as required by ORS 332.167. Community members can see a copy of the radon plan on our website: sheridanjapaneseschool.com. Test results will be made public and posted to the website.

4. Lead in Drinking Water

The Sheridan Japanese School has developed a plan to test for lead in the school water, and if necessary, take corrective action. This plan follows the EPA's 3Ts technical guidance.

- a. All taps used for drinking or food preparation in the building will be tested. The taps to be tested are: Kitchen sink, water fountain, and guest/staff restroom. Tests will be conducted in June 2017 after the end of the school year, and every two years following that. The samples will be analyzed by an OHA-accredited drinking water laboratory.
- b. If more than 20 parts per billion is found in any tap, access to that tap will be prevented by shutting off taps and/or covering water fountains. In the event the water fountain is shut off bottled water will be provided to students and staff members.

- c. Results of tests for lead in water will be available to students, families and community members as soon as they are available. Results will be e-mailed to families and will also be available on the school website.
- d. Should any lead be found, the sources of lead in the plumbing will be replaced.

5. Lead Paint

The Sheridan Japanese School building was built in 2003, and is not subject to the Renovation, Repair and Painting Program Rule.

6. Integrated Pest Management

The Sheridan Japanese School has adopted an Integrated Pest Management Plan as required by ORS 634.700 through 634.750. A copy of this plan is available on the school website: sheridanjapaneseschool.com.

7. Communication

The Sheridan Japanese School will make all test results and detailed information explaining the test results available to the public within five business days of receiving the results. Results will be made available by posting the results on the school's website, sending notice of the results through e-mail, and making the results available in hard copy at the school office.